



Sample of VE Recommendations

- Use galvanized T&C pipe on domestic water distribution piping in lieu of copper
- Use regular flush valve in lieu of auto flush valve.
- Connect over-flow storm drain to storm leader.
- Delete variable speed drive from chillers.
- Winterize one cooling tower in lieu of three towers
- Use victaulic type pipe on chilled water & condenser water piping.
- Combine mixing boxes.
- Use 2" wall air handling units in lieu of 4" wall
- Use a non-ducted return.
- Use non air-conditioned stair pressurization units.
- Eliminate DX back up from computer room air conditioners.
- Use plastic coated duct in lieu of stainless steel in labs.
- Reduce amount of heat recovery CFM.
- Use fan powered VAV on perimeter in lieu of FTR